



Inspection Certificate

Work Order # 31956643

Site Name and Site Address

SOULBURY PARISH COUNCIL

VILLAGE HALL, HIGH ROAD, SOULBURY NR LEI, BEDS, , LU7 0BX

Summary of Work Performed

PREVENTATIVE MAINTENANCE VISIT

Fire extinguisher missing on site, replaced at time of the service.

Work Order Details

Contract No:	2355460-Plan 7 FP3 Ex KFPS	Work Done Description:	Extinguisher Routine Service
Off Site Time:	26/01/2023 15:56	Technician:	Jason Hought
Service PO #:	NA Jax Crack	Sales PO #:	

Job Summary - Service

Description	Condition	Quantity
CO2	Basic Service	1
Fire Blanket	Basic Service	1
Water	Basic Service	2
CO2	Unit not Found. Call When It Is Available	1

Unless recorded as non-conforming the inspection and service is carried out in accordance with BS5306 Part 3 (Portable Fire Extinguishers) or, BS5306 Part 1 (Hosereels) or, to agreed requirements as appropriate.

Parts/Activity

Description	Quantity	
PIN & OK INDICATOR GENERIC	1	Contract Rate Applies
EC20 S/HORN WASHER	1	Contract Rate Applies
FX OK DISC	2	Contract Rate Applies

Sales Summary

Description	Quantity	Unit Price (GBP)	Total Price (GBP)	Reason
EC20C 2KG CO2	1	288.25	288.25	Replacement
EXTN INITIAL SERVICE FEE (REGI	1	2.29	2.29	Replacement
	Total	290.54	290.54	

Customer Signature

In the event of any sales at the time of servicing all sales will be supplied subject to Chubb Fire standard terms and conditions of sale. A copy of which I acknowledge has been supplied to me at the time of this service.

Customer Name: Jax Crack

Title: Soulbury Parish Council

Customer Signature:

Date: 26/01/2023 15:51

Thank you for your business! Satisfied customers are our highest priority. If you have any questions or comments please call us on 0344 879 1666.

Chubb Fire & Security Limited Registered Office:

Littleton Road, Ashford, Middlesex TW15 1TZ. Registered in England and Wales under company number 524469

Email:

Website: www.chubb.co.uk